



GOVERNMENT OF TRIPURA
DIRECTORATE OF FIRE & EMERGENCY
SERVICES
AGARTALA : TRIPURA



Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website:www.fireservice.tripura.gov.in

No: FSCTFES/2023/00073

Dated: 03/11/2023

Sub: FIRE SAFETY CERTIFICATE

Certified that the building or premises as mentioned below have complied with the fire prevention and fire safety requirements in accordance with the conditions laid down in the relevant portions of Part-IV of the latest National Building Code and the Tripura Building Rules and that the building/ premises is fit for occupancy class Educational for a period of 3 (three) year(s) in accordance with renewal from time to time.

Name of the Applicant:-	Amulya Debbarma				
Name of Owner with Plot details:-		S. No.	Owner Name and Address		
		1.	ত্রিপুরা সরকার		
		S. No.	Plot No	Total Area	Classification
		1.	4664	0.03	----
		2.	4674	3.05	নাল
		3.	4676	0.01	নাল
		4.	4677	0.01	নাল
		5.	4687	0.8	নাল
Name of the Property/ Organization/ Commercial establishment	Tulashikhar Rajnagar H.S School				
Address of the Building/ Premises:-	Ram Dewan Chowdhury Para Habitation, Rajnagar Village Council, Tulashikhar Bac Block, Post Office Rajnagar Khowai B.O - 799207, Khowai District, Tripura.				

Director,
Fire & Emergency Services,
Or Authorized Signatory
Tripura : Agartala

This certificate will expire on 03/11/2026

Conditions for the Validity of Fire Safety Certificate (NOC).

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to brim.
5. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
6. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

This Fire Safety Certificate is issued subject to the condition that it shall be obligatory for the applicant to strictly adhere to all relevant legal provisions relating to the premises for which this Fire Safety Certificate (Fire NOC) is issued. It shall be the responsibility of the applicant to get all the plots of land, as certified to be under the ownership of the school, to be mutated and recorded in its favour.